

### The Nimbus™ II Central Control System

Easy, Intuitive Map-Based Irrigation Control. Now with Rain Watch.™

#### Nimbus II

#### New Standard Mapping Features Simplify Control

Nimbus™ II allows you to integrate a custom map of your course using GPS or AutoCAD drawings\*, or by importing a BMP or TIFF file. With your computerized course map, you can zoom-in to monitor every detail of your course. Determine individual rotor activity, monitor pump station activity and control the flow of water graphically. Just double-click on a station for a complete status report.

#### Start Without Reading A Manual

Rain Bird is the first in the industry to offer an integrated computerized set-up program. Quick Start™ is a training tool that guides the first-time user through the initialization and start-up of Nimbus II. Quick Start even helps users build their first customized programs and import a map—one step at a time. So, you can quickly get the system up and running without having to read through manuals or attend week-long programming classes. This startup program will teach you how to assign start and finish times to clearly define your watering window. And because each schedule can run up to 12 starts, many different turf growing conditions can be taken into account: germination, clay soil and steep slopes.

#### Make The Most Of Your Irrigation System

Nimbus II can operate 50 programs and 50 schedules per program at one time. Satellites or decoders can be assigned to multiple schedules, allowing you the flexibility to optimize costly hardware. The Course Monitor™ screen provides a graphical real-time view of the course with the ability to monitor activities at a glance.

**Rain Watch™** is an exclusive new feature that is so unique it has a patent pending. Rain Watch is an intelligent rainfall reaction system that uses up to four tipping bucket rain cans to detect and react to local rainfall. For short duration cloudbursts, Rain Watch suspends

irrigation while simultaneously measuring the real time rainfall. When the storm passes, irrigation is resumed with station runtimes reduced by an amount equivalent to the measured rain. In case of extended rainy weather, irrigation will be cancelled for a user-definable period of time.

**Flo Graph™** allows visibility of real-time graphics with individual station information presented in colorful charts. This feature monitors each or all pumps for reliable results.

**Flo-Manager®** balances system demand at maximum capacity with the efficiency of the pump station and delivery network. By staging pumps, Flo-Manager maximizes system output without causing undue stress to your pump system and components. It's sure to help lower water demand, reduce system wear and tear and save energy—year after year.



**Minimum ET™** is another new feature that helps promote healthy turf by supporting advanced ET management techniques. With the Minimum ET feature a superintendent can define a minimum ET threshold value that must be met before irrigation will take place. Minimum ET values can be assigned globally so they affect all programs, or individually by programs for the ultimate in ET management.

**Cycle + Soak™** works with Flo-Manager to achieve maximum efficiency and conservation. It helps you control water application on slopes and in areas with poor drainage. Cycle + Soak maintains the pumping station demands while preventing over application in those challenging areas of the course.

**Water Budgeting** allows you to react to changing conditions with ease. Make specific adjustments to the entire system, a single program or schedule—from 0 to 300 percent.

**Virtual Weather™** provides Rain Bird the exclusive ability to generate evapotranspiration (ET) rates from user-defined values or optional Weather Station sensor data of wind, humidity, temperature, solar radiation and rainfall. This optional feature allows customized and intelligent ET creation for every application with or without a weather station.

**Smart Pump™**—Rain Bird's Smart Pump Software links your pump station to your central control system providing real time communication and optimizing your irrigation cycle. Smart Pump also has the ability to monitor and react to changes in station capacity. Should the pump station capacity increase or decrease, the software adjusts the irrigation cycle based on this change. (Optional)



**Direct Manual Access™** permits activation of any station simply by clicking on that station.

**Smart Sensor™** management supports static and dynamic (flow) sensors anywhere for real-time response to golf course conditions.

#### Works With Or Without Satellites

The optional hybrid modular software interface of the Nimbus II central control system gives you ultimate flexibility when choosing satellites and decoders for your course. Two-wire satellites, wireless satellites and decoders can all be used together with Nimbus II. It is the only system with the unique ability to operate the Rain Bird field decoders and Rain Bird satellites to provide efficient irrigation throughout your course. If you prefer, Nimbus II can control up to 224 Rain Bird PAR+ ES, PAR+ES LINK, PAR+, MSC+ and COM satellites, in addition to PAR+ LINK, MSC+ LINK and COM LINK sats.

#### Meet Regulatory Requirements

Nimbus II makes it easier to satisfy increasing regulatory requirements regarding water usage. Its record-keeping function in Print Office™ allows you to track the amount of irrigation that has been applied throughout the course for days, weeks and months at a time. Nimbus II's true, two-way communication accurately

\*In order to create GPS and AutoCAD maps, it may require a designer.



logs station run time for precise data gathering. This data can be moved from one application to another so you can easily use it in reports that are generated in another program.

## ***Get Precise Control At An Affordable Price***

Don't let the easy-to-use, no-nonsense controls fool you. The powerful mapping function of Nimbus II offers big league flow management, Cycle + Soak, Smart Sensors, Smart Weather™ adjustments and control of Rain Bird's optional on-site Weather Station. Its superior mix of high-end features, graphic controls and affordable pricing make Nimbus II the perfect choice for superintendents who demand excellence.

## ***Offers International Applications***

In addition to English, the language of the Nimbus II can be changed to Spanish, French, German, Italian, Swedish, Portuguese, Korean, Japanese and Chinese. It can even use standard metric measurements to regulate hydraulic flow, eliminating the need for time-consuming conversions.

## ***Control From Anywhere On The Course***

The Rain Bird FREEDOM™ System adds a greater level of control to your Nimbus II system. This optional, handheld, two-way radio allows you to communicate with Nimbus II to stop, start or continue water application. It will also give you spot water without having to sit down in front of the computer. Add a FREEDOM-Pad™ system and gain more control with visual activation.

## ***Specifications***

The computerized central control system shall be the Rain Bird Nimbus™ II as hereinafter specified. It shall be capable of controlling three (3) independent, 18-hole golf courses, each consisting of seven user-definable areas. The central shall include the Rain Bird "P" Series computer system, as hereinafter specified. The central equipment shall include a satellite or decoder interface unit, an uninterruptible power source, a power circuit surge arrestor and a grounding network grid with surge arrestors, all as hereinafter specified.

All Nimbus II central control systems shall be Hybrid compatible. The Nimbus II Hybrid systems will have the ability to control 3 different types of communication interface devices, three of the same type of communication interface or a combination of either. A Nimbus II Hybrid software module and additional Interface units (MIM, MIM LINK or LDI) must be ordered.

**Nimbus II Software**—The Nimbus II software shall operate in the Microsoft® Windows® 98, SE, 2000 or XP Professional environment. In a

standard configuration, Nimbus II shall be capable of controlling any one of (3) types of field unit systems; (1) hard-wired satellite field units; (2) radio operated, LINK satellite field units, or (3) hard-wired decoder field units in standard configuration. With the addition of a Hybrid software module any combination of up to 3 of these units can be controlled. The hard-wired, satellite-based systems shall be capable of controlling 28 channels, on each of eight (8) different two-wire communication paths. Each group shall be capable of controlling a maximum of 672 satellite stations or a total of 5,376 satellite controller stations. The radio LINK type satellite system shall be capable of controlling four (4) different groups of LINK satellites. A total of 112 LINK satellites shall be capable of controlling 24 stations (max.) each. Total system capacity shall be 5,376 (using 2 MIM-LINK interface units with the Hybrid software module) LINK satellite stations. The two-wire satellites and LINK satellites have the capability of expanding to 72 stations maximum, in modules of 8 stations per additional module. Total number of station outputs, for each satellite, shall be shown on the drawings and/or as directed. The decoder-based system shall have the capacity to control a maximum of 1,500 (using 3 LDI interface units with the Hybrid software module) single decoders and activate up to 3,000 solenoids.

Continuous on-line communication, between central computer/interface unit and the field satellite or decoder units, shall provide true central control. Continuous field unit feedback status information shall be registered at the computer and also at the satellite interface unit. Nimbus II shall be a program/schedule-based system providing maximum flexibility of programming and giving the operator absolute and full control of the entire system. The Nimbus II system shall be capable of unlimited programs residing in the system at one time. Each program shall be further defined by a number of smaller schedules. A maximum of fifty (50) programs and up to 50 schedules may be operated simultaneously. All programming shall be maintained in the computer memory and on the hard drive, from which they shall be executed. Programming shall NOT be down loaded to the field units. It shall NOT be possible to change or reprogram from the field thus assuring the operator full control at all times. A time window may be defined for each individual program, confining its operation to this specific time period. Individual schedules shall be capable of being designated for up to 12 start times within the specified time window for their program. Individual programs shall be capable of being designated for up to 6 start times. It shall be possible to designate the sequence of operation of areas and the sequence of operation of stations in these areas, within a given schedule.

The Nimbus II system shall provide for the selection of three (3) different flow measurement units—U.S. gallons per minute,

cubic meters per hour or liters per second. It shall also provide for the selection of any one of eight (8) different languages for display.

A built-in Flo-Manager® feature shall automatically distribute and limit flow within the system, to eliminate hydraulic overload while maintaining maximum system operating efficiency. The system shall also be capable of entering complete flow management database information for up to six (6) independent pump stations; up to 250 piping network branches and up to 500 flow zones for each pump station. The system shall allow the use of a pump station monitoring software capable of providing real time data exchange with the optional Smart Pump™ feature. This shall result in the highest efficiency of pump station operation, shortest watering cycle time and conservation of energy. During operation, individual flow graphs shall be automatically generated for each of the three- (3) courses, with individual station activity information being presented in colorful charts with a comparison of controlled flow versus actual flow. Flow graphs shall be automatically maintained on file for future access and reference.

The Nimbus II SmartWeather™ optional software module shall monitor and respond to climactic conditions as they occur by tracking evapotranspiration (ET) rates and other sensory inputs. SmartWeather shall also track weather conditions for future reference. SmartWeather shall provide automatic response from user-defined thresholds on up to five (5) Weather Stations. The SmartWeather responses shall be provided to the computer for programmed response and shall be capable of sending an alphanumeric page to the user for alarm conditions.

The Nimbus II system shall also provide for programs to be set to adhere to manual water budgeting; at the system level, at the individual program level and/or at the individual schedule level. A watersaver feature shall provide water budgeting capabilities from 0 to 300% in 1% increments. Automatic rain shutdown shall be possible with the integration of a rain sensor.

A Rain Watch feature shall provide an intelligent rainfall reaction. The Rain Watch feature shall be capable of suspending irrigation during intermittent rainfall, and then resume irrigation with station runtimes reduced an amount equivalent to the rain that has fallen. The Rain Watch feature shall also be capable of canceling irrigation for a user definable time in the event of extended rainy conditions. To use the Rain Watch feature up to four tipping bucket rains shall be installed with one Rain Bird pulse decoder for each rain can.

In addition to calculating runtimes based on measured weather parameters, a Minimum ET function shall be provided which can delay program activation until a user-determined minimum ET threshold has accumulated.

The Nimbus II CYCLE + SOAK™ feature should achieve maximum efficiency and water conservation. It helps control water application on slopes and in areas with poor drainage.

A dry run feature shall provide for testing of a program and will allow the user the ability to make necessary adjustments before actual operation. A printout of the dry run results shall be possible, as well as being displayed on the monitor.

A guided initialization and start-up programming method in Nimbus II shall result in a customized Quick Start™ program that gets the system up and operating in a short time. Built-in rotor database tables shall provide for easy specification of station sprinklers for custom irrigation scheduling. Precipitation rates for each station shall be automatically calculated with the selection of sprinkler model, pattern and spacing. A graphic display of the golf course can be achieved using any of three (3) methods: (1) Create a map using the Scorecard function, (2) Import AutoCAD and GPS as-built drawings, or (3) Import a picture of the course as a BMP or TIFF drawing file. Each hole can be defined to indicate the areas to be irrigated such as greens, tees, fairways, approaches, perimeters, roughs and miscellaneous areas. The system shall provide for multi-station programming and operation of satellite stations. A station data table shall give complete database information for each individual station. A unique QuickIRR™ method of programming shall provide for a quick and easy method to automatically build programs to meet all irrigation challenges and allow programming by specific areas these areas.

The Nimbus II system shall be capable of direct manual access of any stations, at any time. Full system remote control shall be possible with the integration of The FREEDOM™ System and handheld software module. Additionally the FREEDOM-Pad Remote Field Device can be added to Nimbus II for advanced graphical field control. The Nimbus II system shall provide for an individual course, daily and seasonal logs for record keeping and easy compliance with regulatory requirements regarding water usage. A unique Cost Estimator feature shall provide projections of water and power costs for specific irrigation cycles.

The Nimbus II decoder-based system shall provide an automatic decoder and line condition testing program, for easy check-out and troubleshooting of the system.

**Hardware**—Computer-Furnish and install at the central location a Rain Bird “P” Series computer system, consisting of the following minimum specifications:

2.4 GHz Pentium® 4 processor  
512 MB SDRAM  
20 GB EIDE Hard Drive  
1.44 MB floppy disk drive  
Microsoft® PS2 Intellimouse  
56K Internal Modem

DVD/CD-ROM-R/W  
32 MB Video Card  
Sound card  
Speakers  
Quiet Key 104 keyboard  
USB to Serial Adapter  
Color monitor

Preinstalled software shall consist of:  
The Rain Bird Nimbus II program  
Map Import Software  
PcAnywhere Communication software  
Microsoft® Windows® XP Professional

Optional software modules:  
Rain Bird Automatic ET software  
Rain Bird Smart Weather software  
Rain Bird FREEDOM™ handheld software  
Rain Bird Smart Paging software  
Rain Bird Smart Sensors software  
Rain Bird Hybrid software  
Rain Bird Smart Pump software  
Rain Bird Multiple Weather Station software  
Rain Bird Map Layers and Station Resolution software  
Rain Bird Map Utilities software  
Rain Bird FREEDOM-Pad software

**Voltage Stabilizer**—At the central location, furnish and install a combination voltage stabilizer and uninterruptible power source unit. Unit shall have a rated output of 600VA and 400 Watts. It shall be suitable for 50/60 Hz operation with input power of 120VAC. Battery back-up shall have a minimum time of approximately 12 minutes minimum at half load capacity. The unit shall have four (4) electrical outlets.

**Power Surge Arrestor**—At the main electrical panel and on the circuit supplying the central equipment. Furnish and install a Model “Z1” Zap Trap surge arrestor. Unit shall be for 120 Volt, single-phase power rated for 100 Amps. It shall have a discharge capacity of 15,000 Amps at an 8 x 20 second pulse. It shall have a clamping voltage of 130 Volts and a response time of 1.5 N/sec. Surge arrestor shall be as manufactured by TyteWadd Power Filters: [www.tytwadd.com](http://www.tytwadd.com), phone: 417-887-3770.

**System Grounding System**—At the central control location, as close to the interface unit as possible, install a grounding system. Install a standard 12" x 18" x 12" rectangular valve box around the top of any connections in the system to a surge arrestor, and the grounding lug of a piece of equipment or an MGP-1 grounding plate assembly. This shall provide future access to inspect and/or maintain it properly.

A #10 gauge or larger bare copper ground wire shall be run from the grounding lug of the MIM, MIM LINK or LDI interface unit, out and attached to the grounding system. On each two-wire path, coming from the interface unit or LDI and going out to the field satellite units or the field decoders. Furnish and install an MSP-1 surge arrestor, which is to be mounted in an MGP-1 grounding plate assembly that is securely attached to the grounding system. Connect the MSP-1 arrestor into the two-wire

path. A 10 OHMS or less resistance shall be maintained at the grounding system.

**Hard-Wired Interface Unit**—(two-wire satellite system)—The interface unit shall be a Rain Bird Interface Module (MIM) unit with all solid-state electronic circuitry. It shall provide the necessary interface between the computer and the field satellite units. The interface unit shall provide both communication from the computer out to the field satellite units and feedback communication from the field satellite units to the computer. It shall be capable of controlling four (4) two-wire paths of 28 independent channels each. Status lights shall indicate activity on the two-wire paths, as well as to channels being operated on the various two-wire paths and the individual stations in operation on each of these channels. A memory switch shall provide for past performance data. The MIM unit shall be complete with a power supply cord and an RS-232-C communication cable to be connected between it and the serial port of the computer. The unit shall be mounted near the central computer. A #10 gauge or larger bare copper ground wire from the ground lug of the MIM unit should be attached to the grounding system.

**LINK Interface Unit**—(radio LINK satellite system)—The interface unit shall be a Rain Bird “MIM LINK” unit with all solid-state electronic circuitry and two-way radio and receiver, with \_\_\_\_\_ radio frequency. It shall provide the necessary interface between the computer and the LINK field satellite units. The interface unit shall provide true two-way radio communication from the computer out to the LINK field satellite units and feedback radio communication from the LINK field satellite units to the computer. It shall be capable of controlling up to 112 LINK satellites within a maximum of four (4) groups. The MIM LINK unit shall be complete with a power supply cord and an RS-232-C communication cable to be connected between it and the serial port of the computer. The unit shall be mounted near the central computer.

Furnish and install, outside on the building or on an antenna tower, near the central equipment location a Rain Bird model ANT-02, ANT-03 or Yagi type antenna. An RG8 type coaxial cable shall be attached to the antenna and routed into the building near the floor and near the MIM LINK unit location. Furnish and install, inside the building on the wall near the floor, a PolyPhaser Model IS-IE50LU-C1 surge arrestor to which the coaxial cable shall be connected to the antenna terminal on this surge arrestor. Furnish and install from the equipment terminal of the surge arrestor an RG8 type coaxial cable and connect it to the coaxial cable connection on the MIM LINK interface unit. Connect a #10 gauge or larger bare copper ground wire to the antenna and a second ground wire to the ground lug on the surge arrestor. Route each of these ground wires and connect them to the grounding





system. Furnish and install all necessary mounting clamps, brackets, etc. as may be required for the antenna, coaxial cable, ground wires and the surge arrestor. A #10 gauge or larger bare copper ground wire from the ground lug of the MIM LINK interface unit shall be attached to the grounding system.

**Decoder Interface Unit**—(decoder-based system)—The interface unit shall be a Rain Bird Large Decoder Interface (LDI) unit with all solid-state electronic circuitry. It shall provide the necessary interface between the computer and the field decoder units. The interface unit shall provide both communication from the computer out to the field decoder units and feedback communication from the field decoder units to the computer. It shall be capable of controlling, over a two-wire path, up to 500 (max.) single decoders and up to 1,000 (max.) solenoids. The LDI unit shall be complete with 117 VAC power supply cord and a communication cable, which shall be connected between the LDI interface unit and the serial port of the computer.

Connect a #10 gauge or larger bare copper ground wire to the ground lug of the LDI and route it out and connect it to the grounding system.

**PAR+ES Field Satellite Units**—(hard-wired PAR+ satellite system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model PAR+ES two-wire field satellite controllers. Furnish and install each basic satellite field unit for the total number of station outputs indicated on the drawings.

**PAR+ Field Satellite Units**—(hard-wired PAR+ satellite system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model PAR+ PP (plastic pedestal) or PAR+ SS (stainless steel pedestal), two-wire field satellite controllers. Furnish and install each basic satellite field unit for the total number of station outputs indicated on the drawings and/or as directed.

**MSC+ Field Satellite Units**—(hard-wired MSC+ satellite system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model MSC+ PP (plastic pedestal) or MSC+ SS (stainless steel pedestal), two-wire field satellite controllers. Furnish and install each basic satellite field unit to configure it for the total number of station outputs indicated

on the drawings and/or as directed.

**PAR+ES LINK Field Satellite Units**—(radio PAR+ LINK satellite system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model PAR+ES LINK, radio LINK type field satellite controllers. Those satellite units, with radio/modem units, shall be furnished with dome hood type antennas. Furnish and install each basic satellite field unit for the total number of station outputs indicated on the drawings. For those units indicated on the drawings, furnish and install CAM LINK units.

**PAR+ LINK Field Satellite Units**—(radio PAR+ LINK satellite system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model PAR+ LINK PP or PAR+ LINK/R PP (plastic pedestal) or PAR+ LINK SS or PAR+ LINK/R SS (stainless steel pedestal), radio LINK type field satellite controllers. Those satellite units, with radio/modem units, shall be furnished with dome hood type antennas. Furnish and install each basic satellite field unit to configure it for the total number of station outputs indicated on the drawings and/or as directed. For those units so indicated on the drawings, furnish and install CAM LINK units.

**MSC+ LINK Field Satellite Units**—(radio MSC+ LINK satellite system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model MSC+ LINK PP or MSC+ LINK/R PP (plastic pedestal) or MSC+ LINK SS or MSC+ LINK/R SS (stainless steel pedestal), radio LINK type field satellite controllers. Those satellite units, with radio/modem units, shall be furnished with dome hood type antennas. Furnish and install each basic satellite field unit to configure it for the total number of station outputs indicated on the drawings and/or as directed. For those units so indicated on the drawings furnish and install CAM LINK units.

**Field Decoder Units**—(decoder-based system)—Furnish and install, where shown on the drawings and/or where directed, Rain Bird Model FD-101 or 102, single decoders, FD-202, double address decoders, FD-401, 4 address decoders or FD-601, six pack decoders. All types of decoders shall be solid-state electronic circuitry and epoxy potted in a sturdy plastic case suitable for direct burial. Each decoder shall be factory set for a specific response code with code number permanently

and prominently marked on the decoder case. Also furnish and install in the two-wire path, where shown on the drawings, Rain Bird Model LSP-1 surge arrestors. One LSP-1 ground wire shall be attached to the solenoid core tube and the other to a 4' copper ground rod, installed near the LSP-1 surge arrestor.

**Wire**—(hard-wired satellite system and decoder based system)—Furnish and install, for the two-wire communication paths, double jacketed type wire, consisting of two tin-coated type UF insulated (4/64" PVC), soft drawn, annealed solid copper conductors. The two conductors shall be color-coded (one RED, the other BLACK). The second outer jacket shall be a solid color, high density, polyethylene insulation. Jacket colors and conductor sizes shall be as shown on the drawings.

**Weather Station**—Furnish and install, where shown on the drawings, a Rain Bird Model WS PRO SH, direct hard wired, or Model WS PRO PH remote telephone operated or WS Pro LT radio operated, On-Site Weather Station. The station shall monitor the following daily critical weather conditions: wind direction, wind speed, solar radiation, air temperature, relative humidity and rainfall. Sensors shall be polled every 5 seconds and in the SH and PH stations the data recorded in a micro-logger located in the Weather Station mast. The SH and PH Weather Stations shall be furnished complete with a transformer and a 12-Volt battery. The WS PRO SH shall also include calling and answering modems. The WS PRO PH shall include an answering modem. The WS PRO LT shall include calling and answering radio transceivers. For the WS PRO PH unit, furnish and install a modem and a dedicated phone line at both the computer location and the Weather Station location. For the WS PRO SH unit, the communication wire between weather station and central computer shall be Belden #9883 direct burial type cable, consisting of three twisted wire pairs and with metal shield. Furnish and install the necessary MSP-1 surge arrestors, to be wired into the communication wire paths and power wires, at both the Weather Station location and at the central equipment location, as well as the required MGP-1 grounding plate assemblies.

Furnish and install a grounding system, at the Weather Station location the same as previously specified for the central grounding system.

**Rain Bird International, Inc.**  
145 North Grand Avenue, Glendora, CA 91741  
Phone: (626) 963-9311  
Fax: (626) 963-4287

**Rain Bird Technical Service**  
(800) 247-3782 (U.S. only)

[www.rainbird.com](http://www.rainbird.com)

**Rain Bird Corporation  
Golf Division**  
6991 E. Southpoint Rd. Bldg. #1  
Tucson, AZ 85706, U.S.A.  
Phone: (800) 984-2255, (520) 741-6100  
Fax: (520) 741-6522  
Email: [rbgolf@rainbird.com](mailto:rbgolf@rainbird.com)

♻ Recycled Paper.  
The Intelligent Use of Water.™—Visit [www.rainbird.com](http://www.rainbird.com)  
to learn more about our efforts.

® Registered Trademark of Rain Bird Corporation  
© 2004 Rain Bird Corporation 1/04

D31645F